



City of St. Augustine Beach

CITY MGR. (904) 471-2122
FAX (904) 471-4108

ENGINEERING (904) 484-9126
jsparks@cityofsab.org

ADDENDUM #1

October 31, 2023

To: Prospective Respondents
From: City of St. Augustine Beach
Subject: BID #23-07; Citywide Pipe and Manhole Lining, Renewal & Rehabilitation Services

This Addendum #1 is issued for further Respondents' information and is hereby incorporated into the RFQ Documents. Each Respondent must incorporate any and all revisions, clarifications, and/or supplemental information provided in all issued addenda with the submitted Qualifications. Respondents must submit a copy of each signed addendum with their Qualifications as provided in the RFQ Documents.

Questions/Answers:

The City provides the following answers to the questions submitted below:

1. Does the City intend to issue multiple contracts for this project?
Answer: Yes. See pages 9 and 20 of the bid document.
2. What is the City's annual budget for this project?
Answer: Approximately \$100,000/year, minimum.
3. Hello, can bidders bid on individual groups, or must a bidder bid on every item?
Answer: See p23, Attachment A: "Bidders are NOT required to bid each item. Enter "No Bid" in place of the unit prices for each item you are not submitting pricing. Award will be based on the Total Unit Price Bid for items A-1 through C-15, with the intent to award multi-year contracts to more than one Bidder."
4. Provide bid tabulation from previous contract.
Answer: There is no previous contract.
5. Is Bid No: 23-07 for Storm Systems only or will this pertain to Sanitary Sewer also?
Answer: Storm systems only.
6. The bid references the ASTM F2551 which is for sanitary sewer.
Answer: Disregard all references to Sanitary Sewer, including ASTM F2551 on p64: REFERENCES: ~~ASTM F2551 Standard Practice for Installing a Protective Cementitious Liner System in Sanitary Sewer.~~

7. What are the approved products pertaining to the MH rehabilitation portion of the project bid?

Answer: See XVI. MANHOLE REHABILITATION, MANHOLE REPAIR MATERIALS, A.

8. What are the specific testing requirements pertaining to the MH rehabilitation portion of the project.?

Answer: See XVI. MANHOLE REHABILITATION, MANHOLE REPAIR MATERIALS, B.

9. Can the city please provide the full bid tabs for a project of similar nature before this project bid to all bidders?

Answer: The City has no projects of similar nature.

10. I'd welcome the opportunity to meet with you to see if our company could possible bid as an alternative to CIPP?

Answer: See p5 SUBSTITUTIONS.

11. Will ASTM F2019 (Ultra Violet Glass Reinforced Pipe) be accepted as "an equal" for F2016 (Felt) for this project??

Answer: See p5 SUBSTITUTIONS.

12. Is there a Pre-Bid Meeting Scheduled??

Answer: No.

13. If we submit bid electronically, do you still need an original bid bond mailed?

Answer: Yes.

14. What is the Engineer's Estimate (budget)?

Answer: None. Bid is for continuing services contracts with multiple companies..

15. What is the contract term? Substantial and Final Completion Time?

Answer: See p11, CONTRACT DURATION & RENEWAL. 3 years with option for one two year renewal.

16. Are there plans or drawings?

Answer: No.

17. Could you please expand on the anticipated "Grant Administration" services included within the Environmental Services listing?

Answer: As part of a requested scope of services/proposal, Consultant assists City with obtaining and/or managing/administering federal or state funded grants.

18. Bid Item A-28 is not industry standard.

Answer: Delete Attachment A, p24, Item I-28 :

Cured-In-Place-Pipe Liner - Furnish and Installation – Stormwater Drainage Infrastructure			
Item	Description	Unit of Measure	Extension
	8" diameter CIPP Liner		
A-26	6.0 mm normal thickness (.236)	LF	\$
A-27	7.5 mm normal thickness (.295)	LF	\$
A-28	9.0 mm normal thickness (.354)	LF	\$
A-29	Sectional Liner, 8' long	EA	\$

19. We have another question concerning the Bypass Pumping & Dewatering, Pay Item referenced Below. Specification states this item is by pump size for dewatering operation. Typical dewatering pump sizes start at 2", 4" 6", etc. Can these pump sizes be added?

Answer: No. Bid is to reflect unit pricing per (X) lineal foot of (Y) diameter pipe for full compensation for all labor, material and equipment to by-pass pump (and dewater) as needed to successfully line and cure the pipe.

20. There doesn't appear to be any 10inch diameter CIPP Lining/ sectional items, Can these be added??

Answer: 10-inch stormwater drainage pipes do not exist in the system. No.

21. Can the above mentioned bid be submitted electronically through DemandStar?

Answer: Yes.

22. Does the City require the original bid bond or can we upload a copy if bid submission can be submitted electronically?

Answer: Original must be submitted.

**SUBMITTAL DEADLINE FOR QUALIFICATIONS REMAINS:
THURSDAY, November 9, 2023 AT 10:00 AM EST**

Respondent Acknowledgment

Signature

Printed Name/Title

Respondent Company Name

**END OF ADDENDUM
NO. 1**