



## Legislation Details (With Text)

<b>File #:</b>	20-739	<b>Version:</b>	1	<b>Name:</b>	
<b>Type:</b>	Contract	<b>Status:</b>		Consent Agenda	
<b>File created:</b>	10/20/2020	<b>In control:</b>		City Council	
<b>On agenda:</b>	11/10/2020	<b>Final action:</b>			
<b>Title:</b>	Approve Change Order #1 to FY20 P.O. 75893 with CE Power Solutions of Florida, Lakeland, Florida, for the re-mobilization and replacement of a Variable Frequency Drive (VFD) component not included in the Original Quote/Purchase Order; To Authorize the City Manager to Execute the Change Order. (Utilities Director)				
<b>Sponsors:</b>					
<b>Indexes:</b>					
<b>Code sections:</b>					
<b>Attachments:</b>	1. CE Power CO 825247.pdf, 2. Original PO 75893.pdf, 3. Notice of Award.pdf				

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

## CITY COUNCIL AGENDA ITEM

Memo Date: October 20, 2020  
Agenda Date: November 10, 2020  
Prepared By: Sean B. McFarland, Water Treatment Manager  
Through: John A. Walsh, P.E., Utilities Director

### Requested Action:

To Approve Change Order #1 to FY20 P.O. 75893 with CE Power Solutions of Florida, Lakeland, Florida, for the re-mobilization and replacement of a Variable Frequency Drive (VFD) component not included in the Original Quote/Purchase Order; To Authorize the City Manager to Execute the Change Order.

### BACKGROUND:

The Dyal Ground Water Treatment Plant operates three (3) large transfer pumps which are used to pump/transfer treated water from the six multimedia filters to the two on-site five (5) million-gallon storage tanks.

On December 11, 2019, City Council approved Agenda Item 19-552 to replace Transfer Pump #3 Variable Frequency Drive component given the pump's continuous operations. CE Power Solutions had to reschedule the installation and programming of the VFD because delays were incurred as a result of Dyal Plant personnel performing additional work to the pump's electric motor.

This Change Order exceeds the original amount approved by council, \$61,276, and will increase the cost of repair / replacement by \$2,704.

Staff is requesting that City Council approve Change Order #1 to FY20 P.O. 75893 in the amount of

\$2,704 to include additional funds for the required re-mobilization and replacement.

**STRATEGIC PLAN CONNECTION:**

N/A

**BUDGETARY IMPACT:**

Budgeted	Yes
If not budgeted, is amendment/transfer attached?	N/A
Amount Requested	\$2,704
Account Number	421-4020-536.46-00
Account Name	Repairs & Maintenance
Source of Funds:	Operating Revenue
Change Order Amount	\$2,704
Original Purchase Order	75,893
Original P.O. Amount	\$61,276
Total number of change orders to date	1
Total amount in change orders to date	\$2,704

**PREVIOUS ACTION:**

On December 11, 2019, City Council approved Bid Award No. B-20-05-COC to replace Transfer Pump #3 VFD with CE Power Solutions, LLC, Tampa, Florida, for the Dyal Water Treatment Plant.

**RECOMMENDED MOTION:**

To Approve Change Order #1 to FY20 P.O. 75893 with CE Power Solutions of Florida, Lakeland, Florida, for the re-mobilization and replacement of a Variable Frequency Drive (VFD) component not included in the Original Quote/Purchase Order; To Authorize the City Manager to Execute the Change Order.